

Attachment #187

Notes:

Minimum of 300,000 gallons available in Raw/Fire Water Storage Tank for fire protection use.

Motor driven and diesel engine driven fire pumps are each 1x100% capacity.

BEP 2 Raw Water and Fire Protection systems are depicted, BEP 2 systems are anticipated to the same as BEP.

Only major valves and piping are depicted, remainder of components are omitted for clarity.

Well pumps are each 1x100%

Yard loops supply hydrants, sprinkler systems, monitors, and deluge systems.

LC = Locked Closed

LO = Locked Open

NO = Normally Open

